



产品认证证书

证书编号：CQC20012267561

申请人名称及地址

环宇集团有限公司
浙江省乐清市北白象温州大桥工业区

制造商名称及地址

环宇集团有限公司
浙江省乐清市北白象温州大桥工业区

生产企业名称及地址

环宇集团浙江高科股份有限公司(V025839)
浙江省乐清市温州大桥工业园区

产品名称和系列、规格、型号

塑料外壳式断路器

HYM1D-250M、HYM1D-250H、HYM1DK-250M、HYM1DK-250H；Uimp:8kV；Ui:1000V；Ue:AC400V/AC690V；In:250A，
过电流脱扣器类型:电子式；M型:AC400V:Ics=Icu:55kA；AC690V:Ics=Icu:5kA；H型:AC400V:Ics:55kA，Icu:85kA；
AC690V:Ics:10kA，Icu:20kA；Icw:5kA/1s；使用类别:B；3P，3P+N(3个保护极，N极常通)，4P(3个保护极，N
极可开闭)，3P、4P适用于隔离用，3P+N不适用于隔离用

产品标准和技术要求

GB/T 14048.2-2008

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求，特发此证。

发证日期：2020年09月27日 有效期至：2023年09月11日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任：_____

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20012267561

NAME AND ADDRESS OF THE APPLICANT

Huanyu Group Company Ltd.
Wenzhou Daqiao Industrial Zone, Beibaixiang, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Huanyu Group Company Ltd.
Wenzhou Daqiao Industrial Zone, Beibaixiang, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Huanyu Group Zhejiang High Tech Co., Ltd. (V025839)
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

HYM1D-250M、HYM1D-250H、HYM1DK-250M、HYM1DK-250H; Uimp:8kV;Ui:1000V;Ue:AC400V/AC690V;In:250A, ETU;M:AC400V:Ics=Icu:55kA;AC690V:Ics=Icu:55kA; H :AC400V:Ics:55kA, Icu:85kA;AC690V: Ics:10kA,Icu:20kA;Icw:5kA/1s; Utilization Category:B;3P,3P+N(With three protective poles,Uninterrupted N Pole),4P(With three protective poles,Switched N pole), 3P、4P: Suitable for isolation, 3P+N: Not-suitable for isolation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.2-2008

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Sep.27,2020

Valid until: Sep.11,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>